


9LCA001000AS COMPONENT LAYOUT



Item #	Description	Part Number
AC	Alarm Card, 120V, SL	B7C51PAA
CB1	Circuit Breaker, 15A	EB152771CMDW
F1	Fuse, 7 Amp <i>(some models, replaces CB1)</i>	FUFNM70G251
MC	Master Card w/photocell	B7C14RAA
MV1-2	Metal Oxide Varistor, 150V 80 Joules	MV150LA20
MV3	Metal Oxide Varistor, 24V 4 Joules	MV24ZA4
SW1	Day/Night/Auto Switch	SZ22030251AK
TB1-E	Terminal Block End (1 total)	TBE230AA
TB1-S	Terminal Block Section (4 total)	TBS213AA01A
TBP	Photocell Terminal Block, 2 Position	TB02B038A07A

Hughey & Phillips
136 East Court Street
Urbana, OH 43078

Phone: 937-652-3500
Fax: 937-652-3508
Website: www.oblighting.com